



- NOTES :-**
- ALL DEVELOPMENT ABOVE THE HIGH WATER MARK IS NOT PART OF THE FORESHORE LICENCE BUT IS SUBJECT OF A SEPARATE PROPOSAL TO AN BORD PLEANÁLA VIA A STRATEGIC INFRASTRUCTURE DEVELOPMENT APPLICATION.
 - THIS DRAWING PROVIDES AN INDICATIVE DESIGN AND CONSTRUCTION SEQUENCE FOR THE IRISH LANDFALL AT CLAYCASTLE. THE DRAWING HAS BEEN DEVELOPED TO AID IN THE ENVIRONMENTAL ASSESSMENT.
 - LANDFALL DESIGN INCLUDING TEMPORARY FACILITIES (SPOIL STORAGE LOCATION) TO BE CONFIRMED IN DETAILED DESIGN. HOWEVER, ALL TEMPORARY WORKS TO BE CONTAINED IN THE COMPOUND FENCING SHOWN.
 - THE CABLE DIAMETERS ARE CURRENTLY UNKNOWN AND ARE SUBJECT TO DETAILED DESIGN. HOWEVER, IT IS ANTICIPATED THAT EACH ELECTRICAL CABLE WILL HAVE A DIAMETER OF BETWEEN 100MM AND 200MM AND THE FIBRE OPTIC LINK WILL HAVE A DIMENSION OF APPROXIMATELY 20MM.

LEGEND :-

TRENCH	HARD SURFACE
TJB	GRASSED AREA
CONSTRUCTION COMPOUND	BUILDING

GEODETTIC DATA:

GIS COORD SYSTEM:	EPSG:	VERTICAL DATUM:	UNITS:
WGS 84 UTM-29N	32629	O.D. MALIN	METERS

DOCUMENT No.	DOCUMENT TITLE
--------------	----------------

REFERENCE DOCUMENTS

THE INFORMATION CONTAINED ON THIS DRAWING IS CONFIDENTIAL, UNLESS AGREED OTHERWISE (BY A RELEVANT CONTRACT OR IN WRITING) THIS DRAWING SHALL REMAIN THE PROPERTY OF WOOD PLC. WITHOUT PRIOR AGREEMENT THE DRAWING SHOULD NOT BE USED FOR ANY OTHER PURPOSE THAN THAT AGREED, NOR SHOULD THE DRAWING BE REPRODUCED IN WHOLE, OR PART, OR PASSED ONTO ANY THIRD PARTY.

REV	DATE	REVISION	BY	CHK	ENG	PM	CLIENT
D	10.06.21	ISSUED FOR FINAL SUBMISSION					
C	09.03.21	ISSUED FOR DRAFT SUBMISSION					
B	24.02.21	ISSUED FOR REVIEW					
A	23.02.21	ISSUED FOR INTERNAL REVIEW					



PROJECT	CELTIC INTERCONNECTOR	FOR PLANNING PURPOSES ONLY - NOT FOR CONSTRUCTION -
CLIENT	EIRGRID	

TITLE								IRISH SHORE APPROACH AND LANDFALL AT CLAYCASTLE OPTION 2 – PHASE ONE							
DATE		22.02.21		PROJECT No.				SCALE		AS SHOWN		SHEET		01	
DATE		22.02.21		400584				CAD REF.		400584–PL–DWG–007_D					
DATE		22.02.21		DRAWING NUMBER								REV.			
DATE		22.02.21		400584–PL–DWG–007								D			