

MARINE LICENCE VETTING COMMITTEE:

**Re: DECLG file ref FS006062, MS 51/8/1360 Outfall stormwater pipe at Loughbeg,
Ringaskiddy, Co. Cork**

Request for observations from Ms. Shirley Kennedy (DECLG) dated 2.2.2016

This application relates to retention of existing, constructed and licenced outfall and to re-licencing to new ownership.

Inland Fisheries Ireland has no issues with this foreshore licence application

James J. King (IFI R&D) and Michael Mc Partland (IFI Macroom)

Inland Fisheries Ireland

8.2.2016

CC Terry Mc Mahon MLVC;

6062

Marine Survey Office,
Abbey View House,
Ballyshannon,
Co. Donegal
Ireland.

Tel: 353-071-9822400

Fax: 071-9822439

Memorandum to	EH & LG- Foreshore Section
Attention	Shirley Kennedy
Fax No	6782159
From	Nicholas W. Cantwell
No of Pages	1
Date	10 February 2016
Reference	FS 006062 Renewal of lease for existing outfall pipe. Ringaskiddy. Co. Cork
CC	

- This office has no objections from a navigational viewpoint to the above application.
- The divisional engineer should be contacted for opinion.

Yours faithfully



Nick Cantwell (Capt.)
Nautical Surveyor

¹ This document (including all pages transmitted with this document) is for the addressee(s) only named above. It contains confidential information. It may also be covered by the Official Secrets Act. Any dissemination or use of the contents by persons other than the addressee(s) is prohibited. If you have received this transmission in error, please notify the sender immediately.

Assumpta Drake

From: Alan Cogan
Sent: 10 March 2016 12:29
To: Assumpta Drake
Cc: Madeleine Healy
Subject: RE: FS006062, MS 51/8/1360 Outfall stormwater pipe at Loughbeg, Ringaskiddy, Co. Cork
Assumpta

I have examined the contents of this email and note that it is for the application for :

Renewal of an existing license for discharge of storm water runoff via an existing 300mm Dia. Pipe.

Pleased note the following points:

- This pipe discharges into Lough Beg adjacent to the Depuy plant on the western side of the Plant.
- There is an existing headwall at the discharge point
- No additional construction works will be undertaken as a result of this application for renewal
- No additional works will be undertaken as part of this application process.
- There is an existing petrol interceptor on the storm line.
- A previous license was licensed to Pfizer under MS51/8/1069

In relation to the application I have no comment to make save to say that the Petrol Interceptor should be regularly maintained and inspected to confirm it is functioning properly.

- Please revert should you require any additional information.

-
Regards

Alan Cogan
Executive Engineer
Carrigaline AEO
Church Road
Carrigaline
Co. Cork
☎ 021-4371800 ✉ alan.cogan@corkcoco.ie

Cork County Council is a CPD Accredited Employer

10/03/2016

Re: Foreshore Licence application FS006062 at Lough Beg ,Ringaskiddy, Cork

A Chara

On behalf of the Department of Arts, Heritage and the Gaeltacht, I refer to the above.

Outlined below please find the Nature Conservation observations.

The Department have no further Nature Conservation comments on the above application.

Mise le meas,

Simon Dolan
Development Applications Unit
Department of Arts, Heritage and The Gaeltacht
Newtown Road
Wexford

Shirley Kennedy
Foreshore Unit
Department of Environment, Community & Local Government
Newtown Road
Wexford

Your Ref: **FS006062**

Our Ref: **FW 8/58**

Re: **Outfall stormwater pipe at Loughbeg, Ringaskiddy, Co. Cork**

Dear Shirley,

Further to your e-mail dated 2nd February 2016.

On the basis of the information provided the Department has no objections to a Foreshore Lease/Licence being granted.

Yours sincerely,

Liz Hayes

Liz Hayes
Aquaculture and Foreshore Management Division
Dept of Agriculture, Food and the Marine
National Seafood Centre
Clonakilty
Co Cork
023-8859533

Department of Agriculture, Food and the Marine

Shirley

DuPuy (Ireland) Ltd has made an application for the retention and use of an existing outfall pipe at their plant at Loughbeg, Rinagskiddy, Co. Cork. The pipe is used for the discharge of surface water runoff from the car park onto the foreshore. As the outfall pipe has already been installed and has been in use since 1998 no "new" works are intended to take place on the foreshore.

On the basis of the above I have no objections to a licence being granted and recommended that the following conditions should be included in any licence that may issue:

1. The Licensee shall ensure that there will be no contaminants of any kind discharged to the marine environment and will, in particular, ensure that surface rain water from the surfaced car park shall be routed through a petrol interceptor

2(1). Subject to subparagraph (2) the licensee may use an area of foreshore surrounding the said outfall pipe for the purpose of maintaining in continuous working order the said outfall pipe and for no other purpose whatsoever.

2(2) The licensee shall minimise disturbance to the said foreshore as much as possible during maintenance and shall reinstate to the satisfaction of the Minister any foreshore disturbed as a result of the said maintenance.

Terry